WATER ASSESSMENT REPORT

Jalsenx
Intelligent Water Technologies



WELCOME HOTEL
AHMEDABAD

WELCOMHOTEL
BY ITC HOTELS
ASHRAM ROAD AHMEDABAD

FAUCET & SHOWER FLOW ASSESSMENT

Jalsenx conducted an on-site flow assessment to evaluate water-saving potential using faucet aerators and a shower flow regulator without compromising user experience.

SAVINGS PROJECTION	ESTIMATED WATER SAVINGS	ESTIMATED ANNUAL SAVINGS	ESTIMATED PAYBACK TIME
100 UNITS	2,190 KL / YEAR	₹ 39,420	3 MONTHS
(Based on projection)	(With selected combination)	(With selected combination)	(Based on total investment)

1. MEASURED RESULTS – FLOW RATES

FIXTURE / PRODUCT	BEFORE (LPM)	AFTER (LPM)	WATER SAVING (%)
4 LPM FOAM AERATOR (OPTION 1)	7.2	4.2	42%
2 LPM SPRAY AERATOR (OPTION 2)	7.2	2.4	67%
SHOWER FLOW REGULATOR	10.8	6.6	17%

SELECTED SOLUTION FOR SAVINGS CALCULATION

OPTION 1
4 LPM FOAM AERATOR
Flow Reduction 42%

OR

OPTION 2
2 LPM SPRAY AERATOR
Flow Reduction 67%

+

SHOWER FLOW REGULATOR (Hand Shower)
Flow Reduction 17%

One aerator (either Option 1 or Option 2) will be installed along with the shower flow regulator.

2. ANNUAL SAVINGS POTENTIAL (BASED ON 100 ROOMS)

CONFIGURATION	WATER SAVED (KL / YEAR)	ANNUAL COST SAVINGS (₹ / YEAR)	PAYBACK PERIOD
4 LPM Foam Aerator + Shower Regulator	2,190	₹ 39,420	3 MONTHS
2 LPM Spray Aerator + Shower Regulator	3,504	₹52,542	2 MONTHS

3. COMPARISON AT A GLANCE

PARAMETER	EXISTING (WITHOUT REGULATORS)	WITH 4 LPM + SHOWER REGULATOR	WITH 2 LPM + SHOWER REGULATOR
Tap Flow Rate (LPM)	7.2	4.2	2.4
Shower Flow Rate (LPM)	10.8	6.6	6.6
Overall Water Reduction	-	Approx. 42%	Approx. 67%
Water Saved (KL / Year)	-	2,190	3,504
Annual Cost Savings (₹)	-	₹ 39,420	63,072
Estimated Payback Period	-	3 MONTHS	2 MONTHS

** Calculations based on 100 rooms, 20 minutes/day usage per fixture, 365 days/year, water cost of ₹18*

4. CALCULATION BASIS

- 100 rooms with average tap and shower usage of 20 minutes per day
- Tap flow rate: 7.2 LPM (before)
- Shower flow rate: 10.8 LPM (before)
- Water cost: ₹18 per KL

5. RECOMMENDATION

- Use 2 LPM Spray Aerator for maximum water savings (recommended)
- Use 4 LPM Foam Aerator where higher flow is preferred
- Install shower flow regulator in all showers
- Quick payback with long-term savings

Save Water.
Create a Better Tomorrow.

Efficient Solutions for Sustainable Hospitality.

ABOUT JALSENX

Jalsenx provides high-performance, retrofit water-saving aerators and flow regulators for hotels, hospitals, commercial buildings and institutions across India.

Want to know how much can your property save ?

Book a Free Water Assessment →

WhatsApp Us

www.jalsenx.com

Disclaimer: Measured results are based on the assessed fixtures and operating conditions. Actual water savings may vary depending on usage patterns and operating conditions.